



Los Angeles Convention Center

FOGGERS AND LASERS INFORMATION

Effective January 1, 2011

Exhibitors planning to use hazer/fog machines or lasers must obtain approval from the Los Angeles Fire Department (LAFD) Fire Inspector. Requests must be in writing and must include the numbered information listed below each heading. Also listed below are rules and procedures for using the respective equipment at the Los Angeles Convention Center (LACC).

Hazer/Fog Machines

1. A written scope of the project detailing the desired effect, the level of effect (heavy, moderate, light), and the proposed dates, times, and duration of each period of operation/ performance
2. Drawings showing placement of machines and areas targeted for effect
3. Quantity of machines and type (model) of machines
4. Name of fogging agent (liquid/chemical/gas) and description of the container the agent comes in (1-gallon bottle of Roscoe DF-50, 100lb canister of liquid Nitrogen, etc.)
5. A Material Safety Data Sheet (MSDS) for the fogging agent and/or any other liquid or gas to be used

The LAFD requires that a test be performed to assure the level of fog created will not affect the building's fire/smoke detection system. Arrangements must be made at least 48 hours in advance to schedule a test. Projects found to affect the fire/smoke detection system "may" be approved depending on circumstances, overall affect on the system, and the exhibitor's ability to meet conditions outlined by the Fire Inspector. Projects affecting the system that are approved will be subject to LACC labor charges to work on or adjust the fire/smoke detection system, and related charges for hiring a Fire Inspector to monitor the project.

Foggers/hazers must use fogging agents that are non-toxic and present no harmful effects. Fogging agents and the respective use thereof shall be such that no oily residue is deposited on carpet or other walking surfaces that could potentially cause slip & fall hazards, or be deposited on any of the surfaces of the building.

If pressurized containers/vessels are approved for use, containers must be protected from physical damage and secured from falling or overturning. The quantity of containers allowed in the exhibit hall or meeting room shall be determined by the Fire Inspector (generally no more than one days use). Additional containers must be stored outside of the facility in a designated area. Exhibitors must make arrangements with the Freight contractor for storage and delivery of containers. Deliveries must be made during NON-show hours.

Exhibitors and production staff are responsible for operating foggers/hazers; in accordance with all federal, State, and local laws & codes, within manufacturers specifications, within the parameters of the Fire Inspector's approval and within the requirements set forth in this document.

Lasers

1. A written scope of the project describing the desired effect, level of effect, dates/times and duration of each period of operation/performance
2. Drawings indicating the placement (location) of lasers, mirrors and the entire path and target area of the beams
3. Quantity of machines and type (model) of machines
4. Electrical service required for each machine (volts, amps, and phase)
5. Method of cooling (self cooling, water cooled, Nitrogen cooled, etc.)
6. Name of any liquid/chemical/gas proposed for use, description of the container it comes in, and the respective Material Safety Data Sheets (MSDS)
7. Name of company and person(s) certified to operate the laser(s), as well as a copy of their FDA laser operation certificate

The LAFD requires that a demonstration be conducted to evaluate the laser production prior to the opening of the show. Arrangements must be made at least 48 hours in advance to schedule a demo.

Lasers, mirrors, and other related equipment must be placed in approved locations and targeted in such a manner that prevents the laser beams from coming in contact with any personnel. Lasers are prohibited from targeting any area in which persons may be present such as LACC catwalks, meeting rooms, elevated platforms, etc.

Lasers requiring large volumes of water for cooling may be required to use a recirculation system to conserve water.

If pressurized containers/vessels are approved for use, containers must be protected from physical damage and secured from falling or overturning. The quantity of containers allowed in the exhibit hall or meeting room shall be determined by the Fire Inspector (generally no more than one days use). Additional containers must be stored outside of the facility in a designated area. Exhibitors must make arrangements with the Freight contractor for storage and delivery of containers. Deliveries must be made during NON-show hours.

Exhibitors and production staff are responsible for operating lasers; in accordance with all Federal, State, and local laws & codes, within manufactures specifications, within the parameters of the Fire Inspector's approval and within the requirements set forth in this document.

For questions and/or more information please contact:

Tom Fields
Building Superintendent
Show Operations
Los Angeles Convention Center
1201 S. Figueroa Street
Los Angeles, CA 90015
(213) 741-1151 Ext. 5609
Fax: (213) 765-4267
Email: Tfields@lacclink.com

Clinton Pruiet
Fire Inspector
Public Assembly
Los Angeles Convention Center
1201 S. Figueroa Street
Los Angeles, CA 90015
(213) 741-1151 Ext. 5370
Fax: (213) 765-4266
Email: cpruiet@lacclink.com